

Buckingham Township Fenton's Corner Water System

2021 Annual Drinking Water Quality Report – PWSID #1090165

Spanish (Español)

Este informe contiene información muy importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains very important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

Is my water safe?

Last year, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Buckingham Township vigilantly safeguards its water supplies and we are proud to report that our system did not violate a maximum contaminant level in 2021.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Where does my water come from?

Our water source is from two groundwater wells M1 (source 001) and M2 (source 002) located on the western side of the subdivision serve this system.

Source Water Assessment and its availability

Source water assessment was completed by the Penn State Environmental Resource Research Institute and received from PA DEP in June of 2007. Copies of the complete report are available for review at the PA DEP Southeast Regional office, Records Management Unit at (484) 250-5910.

Educational Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater run-off, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish the limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Water System Information

If you have any questions about this report or concerning your water utility, please contact Stephen Clark (215-794-8834). We want our valued customers to be informed about their water utility. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. Upcoming meeting dates are listed on the Township website at www.buckinghampa.org.

Other Information

Four unregulated secondary contaminants were detected in April of 2020 – iron at 0.97 ppm, chloride at 50.1 ppm, sulfate at 27 ppm, and zinc at 0.03 ppm. The secondary maximum contaminant levels (SMCLs) are as follows: iron (0.3 ppm), chloride (250 ppm), sulfate (250 ppm), and zinc (5 ppm).

WATER QUALITY DATA

The Fenton's Corner Water System is routinely monitored for constituents in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1st to December 31, 2021. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table. Samples collection and testing was conducted by Analytical Laboratories, Inc. (215) 723-6466 during 2021.

DISINFECTANTS & DISINFECTION BYPRODUCTS

Chemical Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Violation Y/N	Sources of Contamination
Chlorine (as CL2)	MRDL =4	MRDLG =4	1.87	1.01 - 1.87	ppm	N	Water additive used to control microbes.
Total Trihalomethanes (TTHMs)	80	N/A	13.1	12.1 - 13.1	ppb	N	By-product of drinking water chlorination.
Chemical Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Violation Y/N	Sources of Contamination
Nitrate	10	10	0.86	0.64 - 0.86	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Barium	2	2	0.22	0.18 - 0.22	ppm	N	Discharge of drilling waste, Discharge from metal refineries; Erosion of natural deposits

ENTRY POINT DISINFECTION RESIDUAL

Chemical Contaminant	MinRDL	Lowest Level Detected	Range of Detections	Units	Violation Y/N	Sources of Contamination
Chlorine	0.40	1.0	1.0-2.1	ppm	N	Water additive used to control microbes.

LEAD AND COPPER

Chemical Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N
Copper (2020)	1.3	1.3	0.04	ppm	0 out of 5	N

Testing was conducted for a broad range of contaminants in 2021 which were not detected in our samples, including nitrite, Haloacetic acids, total coliform presence, volatile organic chemicals, and several inorganic compounds (including arsenic, chromium, cyanide, fluoride, mercury, and nickel).

Information about Nitrate

Infants below age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Information about Copper

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Information about Total trihalomethanes (TTHMs): Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Unit Descriptions	
Term	Definitions
ug/L	Number of micrograms of substance in one liter of water
ppm	Parts per million (ppm) or Milligrams per liter (mg/l)
ppb	Parts per billion (ppb) or micrograms per liter (µg/l)
pCi/L	Picocuries per liter – a measure of radioactivity.
NA	Not applicable
ND	Not detected
NR	Monitoring not required, but recommended.
Important Drinking Water Definitions	
Term	Definition
MCLG	Maximum Contaminant Level Goal – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
MCL	Maximum Contaminant Level – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	Treatment Technique – A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	Maximum Residual Disinfection Level Goal – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MinRDL	Minimum Residual Disinfectant Level – The minimum level of residual disinfectant required at the entry point to the distribution system.
MRDL	Maximum Residual Disinfection Level – The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	Monitored not regulated
MPL	State assigned maximum permissible level

PRSRRT STD
U.S. POSTAGE
PAID
DOYLESTOWN, PA
18901
PERMIT NO. 25

Buckingham Township
P.O. Box 413
Buckingham, PA 18912

Annual Drinking Water Quality Report
Buckingham Township – Fenton’s Corner System